


# US Department of Energy Hydrogen and Fuel Cell Perspectives for Backup Power Applications

U.S. DEPARTMENT OF **ENERGY** | Energy Efficiency & Renewable Energy



## Fuel Cell Backup Power for Telecommunication Base Stations

Wuhan, P.R. China

5/29/2015

Dr. Dimitrios Papageorgopoulos

Fuel Cells Program Manager  
Fuel Cell Technologies Office  
Energy Efficiency and Renewable Energy  
U.S. Department of Energy



*“We’ve got to invest in a serious, sustained, **all-of-the-above energy strategy** that develops every resource available for the 21st century.”*

*- President Barack Obama*


*“As part of an all-of-the-above energy approach, **fuel cell technologies** are paving the way to competitiveness in the global clean energy market and to new jobs and business creation across the country.”*

*- Secretary Moniz,  
U.S. Department of Energy*




Secretary Moniz at DC Auto Show

# Why Fuel Cells and Hydrogen?



**>2x** as efficient as today's gasoline engine



**Key component to a diversified and clean energy strategy**

# FCEVs Reduce Greenhouse Gas Emissions

>50%

from Distributed Natural Gas\*


>80%

from Renewables\*\*  
 (Wind)

>90%

from Renewables\*  
 (Wind)


Well-to-Wheels CO<sub>2</sub> Emissions (in grams per mile) for 2035 Vehicles Technologies, except where indicated



\*Compared to 2012 gasoline vehicle  
 \*\*Compared to 2035 gasoline vehicle

*Substantial GHG reductions with H<sub>2</sub> produced from renewables*


## Fuel Cell Systems Shipped by Application



Navigant Research

*Consistent 30% annual growth since 2010*

## Integrated Work Areas



## 2020 Targets by Application



Fuel Cell Cost	<b>\$40/kW</b>	<b>\$1,000/kW*</b> <b>\$1,500/kW**</b>
Durability	<b>5,000 hrs</b>	<b>80,000 hrs</b>
H <sub>2</sub> Storage Cost (On-Board)	<b>\$10/kWh</b> 1.8 kWh/L, 1.3 kWh/kg	
H <sub>2</sub> Cost at Pump	<b>&lt;\$4/gge</b>	

\*For Natural Gas  
\*\*For Biogas

*Integrated approach to widespread commercialization of H<sub>2</sub> and fuel cells*




1.

## Research & Development

### Cost Reductions

- 50% for fuel cell systems

**\$124/kW** in 2006



**\$55/kW** in 2014\*  
at high volume

\*\$280/kW low volume

- 80% for electrolyzers (since 2002)



2.

## Demonstration

### FCEV Demo

- >180 FCEVs
- 25 stations
- 3.6M miles

World's first tri-gen station

GSE, back-up power app.



3.

## Deployment

### Lift Trucks

- 700 DOE cost-shared deployments led to >7,500 additional purchases

### Emergency Back-Up Power

- 900 DOE cost-shared deployments led to 4,000 additional purchases



~1600

DOE cost- shared  
deployments

2014

>7X  
Increase

>11,500

Additional  
purchases without  
DOE funding

# U.S. Hydrogen and Fuel Cells Progress

## In R&D...

**50%** Cost Reduction in fuel cell systems

\$124/kW in 2006



**\$55/kW**  
today\* at high volume

**2X** Increase in fuel cell durability

**5X** Platinum content reduction in fuel cells

## In the Market...

### FCEVs in the US:

Recently announced



Now Leasing



In Auto Shows



**Public-private partnership addressing infrastructure:**

**H<sub>2</sub> USA**

**4X** Increase in partners and growing since 2013

### State Activities:

- 8 states committed to 3.3 million ZEVs by 2025
- CA has committed to 100 H<sub>2</sub> stations

## Key Challenges

- Fuel Cell Cost and Durability
- Hydrogen Production
- Hydrogen Delivery
- Hydrogen Storage
- Infrastructure
- Manufacturing and supply chain
- Safety codes and standards
- Widespread public acceptance




# Hydrogen Safety Resources

Phase 1  
Spring 2015

Potential  
Future Tools

Share your  
ideas!



*The Hydrogen Tools Portal provides a Centralized Location, Focused Content, a Customizable Interface and Responsive Design, Trusted Communities, and an Expandable Format*

# Fuel Cells for Backup Power: Technical Targets

## \* Technical Targets: Fuel Cell Backup Power Systems Operating on Direct H<sub>2</sub>


Characteristic	Units	2015 Status	2020 Targets
Lifetime	Years	10	15
Durability <sup>a</sup>	hours	2,500	10,000
Energy efficiency <sup>b</sup>	%	50	60
Mean time between failures	years	5	5
Ambient temperature range	°C	-20 to 40	-50 to 50
Noise	dB at 1 m	65	60
Start-up time <sup>c</sup>	seconds	60	15
Availability	%	99.7	96.3
Equipment cost <sup>d</sup>	\$ kW <sup>-1</sup>	3,000	1,000
Maintenance cost <sup>d</sup>	\$ kW <sup>-1</sup> year <sup>-1</sup>	30	20

- Time until 10% voltage degradation when operated on a backup power duty cycle.
- Ratio of DC output energy from the powerplant to the lower heating value of the input fuel (hydrogen), averaged over duty cycle.
- Time indicated is start-up time for the fuel cell. The backup power system, including hybridized batteries, is expected to provide uninterrupted power.
- Excludes tax credits and subsidies.

*\*Preliminary; developed with stakeholder input*

# Market Transformation Deployments


*The funding of over 900 DOE fuel cell backup power systems has led to over 5,500 industry installations and on-order backup power units with no DOE funding*



*The 6,475 backup power fuel cell shipments and units on-order equate to >32,000 kW of fuel cell systems*

# Fuel Cells Provide Resiliency to the Grid

**800**  
Fuel Cells  
for back up power  
**deployed**



at cell phone  
towers  
providing  
electricity



during **1,000**  
Power disruptions  
in **23 states**



AZ	KY	NC
CA	LA	OR
CO	MA	SC
CT	MI	TX
FL	MS	UT
GA	NV	WA
L	N	WY
N	NY	

During  
**Hurricane  
Sandy**



the largest Atlantic hurricane on record



**5 sites**  
operated  
providing power

**for over 100 hours**

as validated by NREL

*Source: "Hydrogen Fuel Cell Performance as Telecommunications Backup Power in the United States"  
NREL/TP-5400-60730*

**1,034 out of 1,047 successful fuel cell starts for back-up power**

# Independent Technology Assessment of DOE-Funded Fuel Cell Backup Power Systems in Real-World Operation Conditions

NREL compiled backup power operation summary 2009 Q1 – 2013 Q4

**1.99**

Installed capacity  
in MW

Systems are operating reliably in 23 states. Reasons for unsuccessful starts include an e-stop signal, no fuel, and other system failures.

**99.5%**

Successful starts

**852**

Systems in operation\*

**4–6**

Average site  
capacity in kW

**2,578**


Start attempts

**65**

Continuous run  
hours demonstrated

**1,749**

Operation hours



\*Not all systems have detailed data reporting to NREL


## Objective

Analysis of the annualized cost of ownership for backup power technologies in different annual runtime scenarios to evaluate the economic value proposition of fuel cell backup power systems.


The ownership costs are based on operation lifetime, efficiency, maintenance, installation, fuel, and incentives.

A detailed report on the assumptions, method, and results is available at:

<http://www.nrel.gov/hydrogen/cfm/pdfs/60732.pdf>



# Backup Power Cost of Ownership: Technology Comparison



	8 Hours	52 Hours	72 Hours	176 Hours
<b>Battery</b>	\$6300	\$24800	\$31300	\$67200
<b>Diesel</b>	\$4700	\$4900	\$4900	\$5300
<b>FC</b>	\$5300	\$6100	\$6100	\$8500
<b>FC*</b>	\$4600	\$5100	\$5100	\$7400




NREL cdp\_bu\_23

\* Fuel cell system with incentives, calculated as 30% of expenditures and capped at \$3,000/kW of system capacity

**Technologies are comparable at continuous 8-hour runtime and battery cost increases significantly for the higher operation scenarios**

## Annualized Cost of Ownership 72-hour Scenario



NREL cdp\_bu\_26

\* Fuel cell system with incentives, calculated as 30% of expenditures and capped at \$3,000/kW of system capacity

\*\*Includes capital costs for fuel storage

**Fuel cell system with incentives can be cost competitive with diesel generators**



# Backup Power Cost of Ownership Analysis: Summary & Outlook

- Diesel generator is one of the lower-cost options, but with additional challenges including: cost of annual maintenance, noise, emissions, low efficiency, and/or poor reliability
- Battery system is likely selection for telecom sites requiring < 8 hours of run time
- Fuel cell capital and installation cost reduction will result in stronger value proposition
- Permitting of hydrogen systems, specifically the inconsistency of how requirements are implemented from site to site and how long the process takes needs development



*For decision makers initial cost is a key driver, but other aspects to consider are permitting, emissions, run time capability, ease of refueling, noise, footprint, and user comfort with the technology*

**Hurricane Sandy (October 2012) was the largest Atlantic hurricane on record.**

**Winds spanning more than 1,100 miles**



**More than \$63 billion in damages**





Major cell phone service disruption  
and power outages



## Wireless Telecommunications

- 25% of cell towers in 10-state area stopped operating
- Cellphone outages reported in more than 150 counties from Virginia to Massachusetts
- Many post-Storm cellphone disruptions caused by battery or diesel backup generators running out of fuel before grid power restored

## Electricity Grid

- In the US, 22 of the 23 400 kW UTC Power (Doosan Fuel Cells) stationary fuel cells in the area provided continuous power to buildings.
  - The only fuel cell to shut down was quickly restarted after a brief repair.

## Wireless Telecommunications

- In the Bahamas, all of Ballard's 17 ElectraGen™-ME systems operated continuously, producing more than 1,200 kWh of electricity.
- In the US, all of the 60+ Altery's backup power systems operated flawlessly.
  - The only wireless cell tower sites that remained operational after Hurricane Sandy were those with backup power fuel cell systems.
- During Hurricane Irene, all 56 ReliOn (Plug Power) systems installed at Sprint Sites operated throughout entire outage duration

*UTC Fuel Cells at Verizon Garden City*



*Altery Fuel Cell*



*ReliOn Fuel Cells at Sprint*




# Thank you

[Dimitrios.Papageorgopoulos@ee.doe.gov](mailto:Dimitrios.Papageorgopoulos@ee.doe.gov)

<http://energy.gov/eere/fuelcells/fuel-cell-technologies-office>


# Backup

Delivery Costs: Compression, Storage and Dispensing (CSD) Cost Breakdown for the Pipeline Scenario (\$2.40/kg total)\*\* Storage



- Compression and Storage comprise approximately **75%** of CSD costs when delivered via pipeline

On-board Storage Costs: 700 bar system cost breakdown at 500,000 systems/year



- Composite materials account for **>60%** of total storage tank system cost
- Carbon fiber precursor is the largest single cost contributor.

**Delivery costs: ~\$2.40 to \$5/gge vs. Target of \$2/gge by 2020**  
**Onboard 700 bar storage costs: ~\$17/kWh vs. Target of \$10/kWh by 2020 (high volume)**


# Hydrogen Production: Cost Status

*Costs analyses provide information that allows for informed, prioritization of funding. Some results indicate major cost drivers are outside the scope of FCTO portfolio.*


**Table 1. Current Status of Projected Pathway-Dependent Hydrogen Production Cost Ranges**

Current H <sub>2</sub> Production Cost <sup>6</sup>	LOW \$/kg	BASELINE \$/kg	HIGH \$/kg
<b>Distributed Pathways</b>			
Distributed PEM Electrolysis	3.40	5.10	6.60
Distributed Bio-Derived Liquids	3.20	6.60	7.90
<b>Central Pathways</b>			
Central PEM Electrolysis	3.40	5.10	6.50
Central Biomass	2.10	2.50	4.20

## Distributed PEM Electrolysis



## BDL Reforming





# Current Status of H<sub>2</sub> Storage Technologies


Storage Targets	Gravimetric kWh/kg (kg H <sub>2</sub> /kg system)	Volumetric kWh/L (kg H <sub>2</sub> /L system)	Costs \$/kWh (\$/kg H <sub>2</sub> )
2020	1.8 (0.055)	1.3 (0.040)	\$10 (\$333)
Ultimate	2.5 (0.075)	2.3 (0.070)	\$8 (\$266)
Projected H <sub>2</sub> Storage System Performance (5.6 kg H <sub>2</sub> usable)	Gravimetric kWh/kg	Volumetric kWh/L	Costs* \$/kWh
700 bar compressed (Type IV)	1.5	0.8	17
350 bar compressed (Type IV)	1.8	0.6	13
Metal Hydride (NaAlH <sub>4</sub> /Ti)	0.4	0.4	43
Sorbent (MOF-5, 100 bar) MATI, LN2 cooling [HexCell, flow-through cooling]	1.2 [1.2]	0.7 [0.6]	16 [15]
Chemical Hydrogen Storage (AB-50 wt.%) [AlH <sub>3</sub> – 60 wt.%]	1.5 [1.1]	1.4 [1.2]	17 [22]

Full comprehensive sets of hydrogen storage targets can be found in the Program's Multi-year Research, Development and Demonstration Plan: <http://energy.gov/sites/prod/files/2014/03/f12/storage.pdf>

- 700 bar and 350 bar compressed H<sub>2</sub> system projections based on 2013 Program Record #13010
  - Materials-based system projections from Hydrogen Storage Engineering Center of Excellence (5/2015)
- \* Projected to 500,000 units / year

# Market Transformation Challenges

- To test emerging applications at the Technology Readiness Level (TRLs) 6-9 level to expand user and servicing expertise



- To test new technology applications in user operating conditions to establish baseline energy efficiency and reliability performance and determine commercial viability

## Examples:



***A 1-kW fuel cell system providing power for this FAA radio tower near Chicago***

(Photo courtesy of ReliOn/Plug Power)




***Material Handling Equipment at work in U.S. airports***

(Photo courtesy of Hydrogenics)


# Market Transformation Deployments

*DOE investment in lift trucks and back up power has led to thousands of industry installations.*




The successful deployment of nearly 700 DOE fuel cell material handling units has led to over 13,500 industry installation and on order units with no DOE funding.

The funding of 907 DOE fuel cell backup power systems has led to over 5,500 industry installations and on-order backup power units with no DOE funding.



## Electricity Grid Outages

- 8.5 million power outages reported across 21 states
- 65% of New Jersey utility customers lost power – 2.6 million homes and businesses
- 25% of West Virginia utility customers lost power



# Accomplishments: MHE Operation Summary 2009 Q4 2014 Q3

Validation of MHE is based on real-world operation data from high-use facilities.

**2,683,567**

Operation hours

**352,527**

Hydrogen fills

**720**

Units in operation\*

**3.7**

Average operation hours  
between fills

**287,967**


Hydrogen dispensed  
in kg

**0.7**

Average fill amount  
in kg

**2.5**

Average fill time  
in minutes



\*One project has completed.  
Only ARRA locations shown